

产品认证证书

II型自愿认证

证书编号: CQC20012276332

发证日期: 2022年11月09日

有效期至: 2031年12月10日

委托人名称 北京国电科创电器有限公司
及注册地址 北京市北京经济技术开发区科创三街3号院1号楼4层401室

制造商名称 北京国电科创电器有限公司
及注册地址 北京市北京经济技术开发区科创三街3号院1号楼4层401室

生产企业名称 北京国电科创电器有限公司
及生产地址 北京市北京经济技术开发区科创三街3号院1号楼401室

产品名称和系列、规格、型号 万能式断路器
GCW5-4000; 详见附件

产品标准和技术要求 GB/T 14048.2-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年12月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0200965

产品认证证书

II型自愿认证

证书编号: CQC20012276332

第1页 共1页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 200965

GCW5-4000

Uimp: 12kV; Ui: 1500V; Ue: AC400V/690V/800V/1000V/1140V;

In: 2000A, 2500A, 2900A, 3200A, 3600A, 4000A;

AC400V: L型: Ics: 85kA; Icu: 85kA; Icw: 85kA/1s;

H型: Ics: 100kA; Icu: 100kA; Icw: 100kA/1s;

AC690V: L型: Ics: 65kA; Icu: 65kA; Icw: 65kA/1s;

H型: Ics: 85kA; Icu: 85kA; Icw: 85kA/1s;

AC800V: L型: Ics: 65kA; Icu: 65kA; Icw: 65kA/1s;

H型: Ics: 75kA; Icu: 75kA; Icw: 75kA/1s;

AC1000V/1140V: L型: Ics: 50kA; Icu: 50kA; Icw: 50kA/1s;

H型: Ics: 65kA; Icu: 65kA; Icw: 65kA/1s; (仅4P)

H型: Ics: 70kA; Icu: 70kA; Icw: 70kA/1s; (仅3P)

过电流脱扣器类型: 电子式;

选择性类别: B类; 极数: 3P、4P; 适用于隔离用



中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC20012276332

Valid from: Nov.09,2022

Valid until: Dec.10,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Beijing Guodian Kechuang Electric Co. Ltd. Room 401, 4th Floor, Building 1, No. 3, Science and Technology Third Street, Beijing Economic and Technological Development Zone, Beijing
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Beijing Guodian Kechuang Electric Co. Ltd. Room 401, 4th Floor, Building 1, No. 3, Science and Technology Third Street, Beijing Economic and Technological Development Zone, Beijing
NAME AND LOCATION OF THE FACTORY	Beijing Guodian Kechuang Electric Co. Ltd. Room 401, Building 1, Yard 3, Kechuang Third Street, Economic and Technological Development Zone, Beijing City
PRODUCT NAME, MODEL AND SPECIFICATION	Conventional Circuit-breaker GCW5-4000 ;see the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.2-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Dec.17,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

申迪

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0200965